

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3295-1454:104 Page 1 of 1

**CATEGORY:** Fire-Rated Doors

**LISTEE:** American Door Manufacturing, 1488 Tillie Lewis Dr., Stockton, CA 95206  
Contact: Randy Neto (209) 941-8852

**DESIGN:** Door, single, pairs, or double egress swinging flush type, wood faces, mineral core fire door.

Core: four pieces proprietary composite mineral core, cut square or flush at joints and edge banding.  
Top & Bottom Rails and Stiles: 1-9/16" x 1" untreated fir.  
Skins: 1/8" Birch veneer plywood.  
Adhesive: National Casein #8580 & BX-800 or approved equivalent adhesive.  
Press Conditions: Cold pressed.

Maximum size not to exceed 4' wide x 10' high for single and 8' wide x 8' high for pairs and double egress. Metal edges with astragal required on pairs and double egress.

**RATING:** 90 Minutes

**INSTALLATION:** In accordance with listee's printed installation instructions, ANSI/NFPA 80, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating/classification, CSFM and EEL labels.

**APPROVAL:** Listed as 90 minutes fire door assembly when installed in a listed frame approved for the type of wall construction.

04-29-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager